





## LIGHT DISTRIBUTION TESTING PARAMETERS

### Luminaire Property

Luminaire Manufacturer:  
Voltage: 119.6 V  
Power: 149.55 W


Current: 1.252 A  
Power Factor: 0.998

### Photometric Results


IES Classification: Type II  
Total Rated Lamp Lumens: 19979.5 lm  
Efficiency: 100%  
Upward Ratio: 1%  
Central Intensity: 6364.13 cd  
Pos of Max. Intensity: H225 V9

Longitudinal Classification: Very Short  
Measurement Flux: 19979.5 lm  
Downward Ratio: 99%  
Luminaire Efficacy Rating (LER): 133.65  
Max. Intensity: 6640.94 cd

Luminous Intensity Distribution Curve



Illuminance at a Distance



### NOTICE FOR USER

- Please turn off power before install or change assembly parts.
- The input voltage and lamps should be matched, after connecting the power line, Please make sure the wiring section is insulated.
- No-professionals, must not install and disassemble the lamps.

### TROUBLE SHOOTINGS

Troubles	Check points
Flickering of the light	Turn off the power and turn on again in 3 minutes. If same phenomena occur, then call agencies.
Out of working	Please check the connection.