

LIGHT DISTRIBUTION TESTING PARAMETERS

Luminaire Property

Luminaire Manufacturer:
Voltage: 119.6 V
Power: 137.76 W


Current: 1.1549 A
Power Factor: 0.994

Photometric Results


IES Classification: Type III
Total Rated Lamp Lumens: 16930.9 lm
Efficiency: 100%
Upward Ratio: 0%
Central Intensity: 3814.62 cd
Pos of Max. Intensity: H22.5 V69

Longitudinal Classification: Medium
Measurement Flux: 16930.9 lm
Downward Ratio: 100%
Luminaire Efficacy Rating (LER): 122.9
Max. Intensity: 5714.61 cd

Luminous Intensity Distribution Curve



The Average Illuminance Effective Figure



NOTICE FOR USER

- Please turn off power before install or change assembly parts.
- The input voltage and lamps should be matched, after connecting the power line, Please make sure the wiring section is insulated.
- No-professionals, must not install and disassemble the lamps.

TROUBLE SHOOTINGS

Troubles	Check points
Flickering of the light	Turn off the power and turn on again in 3 minutes. If same phenomena occur, then call agencies.
Out of working	Please check the connection.